

## STATE OF TENNESSEE DEPARTMENT OF ENVIRONMENT AND CONSERVATION DIVISION OF WATER RESOURCES

William R. Snodgrass Tennessee Tower 312 Rosa L. Parks Avenue, 11<sup>th</sup> Floor Nashville, TN 37243-1534

June 20, 2016

Honorable Justin Hanson 200 W. Washington Ave Covington, TN 38019 CERTIFIED MAIL
RETURN RECEIPT REQUESTED
RECEIPT #7196 9008 9111 3808 3264

Subject:

NOTICE OF VIOLATION NPDES TN0020982 TIPTON COUNTY, TENNESSEE

Dear Mayor Hanson,

On June 16, 2016, the Covington STP appeared on the Quarterly Non-Compliance Report (QNCR) for the first quarter of FY' 16, for effluent violations of Total Residual Chlorine. Please reference attached violation report for further details.

This is a violation of terms outlined in your National Pollutant Discharge Elimination System (NPDES) permit number TN0020982.

If you believe the violations stated above are incorrect, please provide documentation showing the parameters in question to be in compliance. The Division also requests that you submit a written response detailing the cause of the violations and any corrective actions undertaken to correct the violations, or planned corrective actions that are in process. Documentation can be sent to the address listed above and to the Memphis Environmental Field Office located at 8383 Wolf Lake Drive, Memphis, TN 38133.

The Division appreciates your efforts to maintain water quality. Should you have any further questions, please feel free to contact me at (615) 532-1171, or Jessica Murphy at (615) 532-0676.

Sincerely,

Amy Warren

Multi Program Coordinator, Compliance and Enforcement Unit

Division of Water Resources

ATW: EJM

cc:

DWR - EFO - Memphis (via e-mail)

Enforcement File

## Environmental Protection Agency Integrated Compliance Information System

Report Date: 06/16/16 Coordinator's Quarterly Noncompliance Report \*\*\*QNCR\*\*\*

Page 1 of 1

QNCR PERIOD: 1/1/16 to 3/31/16

Major/Minor indicator(s):

NPDES ID(s): TN0020982

Region Code(s):

SNC Only? Yes

State Code(s): TN

Violation Group(s):

State Region:

lesuing Agency:

Permit Type:

TENNESSEE

EACH ITY COMMISTON STD - NIDDES ID: TNIDGGGGG	ECID ID: 120000E23032

BAA I/BAINI	FACILITY	FEDERAL	COMPLIANCE STATUS	State
MAJ/MIN	TYPE	GRANT	COMPLIANCE STATUS	Region
Major	POTW	\$	Noncompliant	05
•			•	

## DMR VIOLATION(S) SUMMARY

Data Run Date: 06/16/16

VIOLATION DATE	LIMIT SET	PARAMETER	MON LOC	ENFORCEMENT ACTION IDENTIFIER	CHANGE OF LIMITS STATUS	VIOLATION				RNC RESOLUTION CODE/DATE/DESCRIPTION			
1/31/16	001-G	50060-Chlorine, total residual	- 1	0.5		E90	R	1/31/16	TRC	1	1/31/16	NC - Unresolved RNC	
12/31/15	001-G	50060-Chlorine, total residual	3 11			E90	R	1/31/16	TRC	11	1/31/16	NC - Unresolved RNC	